

General Environmental Incident Summary

Incident: 1917 **Date/Time Notice:** 5/7/2013 1600 **DEM Incident No:**

Responsible Party: Munich Elevator and Oil Co

Date Incident: 5/7/2013 **Time Incident:** 0600 **Duration:**

County: Cavalier **Twp:** 160 **Rng:** 63 **Sec:** 19 **Qtr:** NE NW NW

Lat: 48.66687 **Long:** -98.82940 **Method:** Derived from TRS

Location Description: Area between Pacific ave, Main St, and 87th ST NE, South of Railroad tracks, west of old elevator. Munich ND 58352

Submitted By: Margaret Hall

Affiliation:

Address:

City:

State:

Zip:

Received By:

Contact Person: John (Jack) Martin
403 Pacific Ave
Po Box 100
Munich , ND 58352

Distance Nearest Occupied Building: 600 Feet

Type of Incident: Tank Leak

Description of Released Contaminant: #2 Dyed Diesel fuel

Volume Spilled: 1000.00 gallons

Ag Related: Yes

EPA Extremely Hazardous Substance: Unknown

Reported to NRC: No

Cause of Incident:

Above Ground Tank is leaking

Risk Evaluation:

no immediate health risks

of Fatalities: 0

of Injuries: 0

Affected Medium: 03 - soil

Potential Environmental Impacts:

contaminated soil.

Action Taken or Planned:

fuel tanks are diked. Fuel is being pumped out of tank and containment. Future actions will be removal of tank. If need be soil can be excavated. Pigs and batts are in place to absorb any product not recovered. When soil firms up tank will be scrapped and area assessed for more investigation/remediation

Wastes Disposal Location: unknown currently

Agencies Involved:

Updates

Date: 5/7/2013

Status: Reviewed - Assigned to NDDoH Division

Author: Cameron, Dave

Updated Volume:

Notes:

This is an above ground fuel tank leak at an elevator. Requesting that Waste Management UST/AST folks do initial investigation. Follow-up and remediation is most likely necessary.