

General Environmental Incident Summary

Incident: 3217 **Date/Time Notice:** 2/27/2014 12:09 **DEM Incident No:**

Responsible Party: Dakota Gasification Company

Date Incident: 2/27/2014 **Time Incident:** 11:00 **Duration:**

County: Mercer **Twp:** 145 **Rng:** 87 **Sec:** 24 **Qtr:** SW

Lat: 47.36200 **Long:** -101.83660 **Method:** Interpolation from map

Location Description: 8 miles NW Beulah, ND; Great Plains Synfuels Plant

Submitted By: Dave Peightal Peightal

Affiliation:

Address: 420 County Road 26

City: Beulah

State: ND

Zip: 58523

Received By:

Contact Person: Vicente Martinez
420 County Road 26
Beulah, ND 58523

Distance Nearest Occupied Building: 0.5 Miles

Type of Incident: basin overflow from cooling tower

Description of Released Contaminant: cooling water

Volume Spilled: 55.00 gallons

Ag Related: No

EPA Extremely Hazardous Substance: No

Reported to NRC: No

Cause of Incident:

Investigating the cause of the minor overflow. Recent winds or higher inventory in the basins could be cause of minor overflow. Incident is being entered in company DIR software.

Risk Evaluation:

no injuries and no impact to people

of Fatalities: 0

of Injuries: 0

Affected Medium: 03 - soil

Potential Environmental Impacts:

cleaning and providing remediation for the soils to remove any potential for groundwater contamination

Action Taken or Planned:

Operations is cleaning up the spill and will be removing dirt as required for reclaiming this area.

Wastes Disposal Location: Any contaminated material will be recycled with the internal process sludge system

Agencies Involved: NDDDES, NDDH

Updates

Date: 2/27/2014 ***Status:*** Reviewed - No Action Required

Author: Roberts, Kris

Updated Volume:

Notes:

Small release to cooling water pond. No followup necessary.