

General Environmental Incident Summary

Incident: 3367 **Date/Time Notice:** 6/25/2014 2225 **DEM Incident No:**
Responsible Party: ONEOK Rockies Midstream
Date Incident: 6/25/2014 **Time Incident:** 1040 **Duration:** 15 minutes
County: Williams **Twp:** 155 **Rng:** 98 **Sec:** 7 **Qtr:** SE
Lat: 48.25610 **Long:** -103.32690 **Method:** Navigation quality GPS
Location Description: Epping Compressor Station
12207 58th St W
Epping ND 58843
Submitted By: Kim Rudningen **Affiliation:** Env. Specialist, ONEOK
Address: 2700 Lincoln Ave SE
City: Sidney **State:** MT **Zip:** 59270

Received By:

Contact Person: Kim Rudningen
2700 Lincoln Ave SE
Sidney, MT 59270

Distance Nearest Occupied Building: 1 Miles **Release Contained:** Yes

Type of Incident: Tank Overflow

Description of Released Contaminant: Methanol

Volume Spilled: 60.00 barrels **Ag Related:** No

EPA Extremely Hazardous Substance: Yes **Reported to NRC:** Yes

Cause of Incident:

The methanol day tank was overfilled and spilled over onto the facility site. This overflow was due to operator error.

Risk Evaluation:

There was no immediate risks associated with this spill

of Fatalities: 0 **# of Injuries:** 0 **Affected Medium:** 03 - soil

Potential Environmental Impacts:

Because the spill was contained to the facility site, there were no adverse environmental impacts to soils or waters.

Action Taken or Planned:

Spill was contained to facility site. The soil was excavated.

Wastes Disposal Location: The soil will be disposed of in a permitted landfill

Agencies Involved:

Updates

Date: 6/25/2014 **Status:** Reviewed - Follow-up Required

Author: Roberts, Kris

Updated Volume:

Notes:

Release, due to a methanol tank overflow, remained on location according to the report. However, overflow is fairly large and a potential hazard to groundwater. Followup is necessary.

Date: 11/20/2015 **Status:** Inspection

Author: Kangas, Kathleen

Updated Volume:

Notes:

Inspected site and spoke to company rep on the phone. Methanol spilled from tank outside of building toward the area between the two entrance ways, and it pooled in that area. All impacted soil has apparently been removed and a report sent to the NDDoH on all remediation done. Please see incident 20150212152216 as site was inspected at the same time for that spill.