

General Environmental Incident Summary

Incident: 3376 **Date/Time Notice:** 7/7/2014 1728 **DEM Incident No:**
Responsible Party: Dakota Gassification
Date Incident: 7/7/2014 **Time Incident:** 1640 **Duration:** 20 minutes
County: Mercer **Twp:** 145 **Rng:** 88 **Sec:** 24 **Qtr:**
Lat: 47.35913 **Long:** -101.83680 **Method:** Interpolation from map
Location Description: Dakota Gassification comapny a valve failure release about 500 gallon SGL
>99% H2O and 0.5% ammonia

Submitted By: Vicente Martinez **Affiliation:** DGC
Address: 420 county road 26
City: Beulah **State:** ND **Zip:** 58523

Received By:

Contact Person: vicente martinez
420 county road 26
beulah, ND 58523

Distance Nearest Occupied Building: 100 Feet **Release Contained:** Yes

Type of Incident: valve failure

Description of Released Contaminant: Stripped gas liquor

Volume Spilled: 750.00 gallons **Ag Related:** No

EPA Extremely Hazardous Substance: No **Reported to NRC:** No

Cause of Incident:

valve failure on heat exchanger

Risk Evaluation:

No

of Fatalities: 0 **# of Injuries:** 0 **Affected Medium:** 07 - Air, Water, and Soil

Potential Environmental Impacts:

claned up immediatley contained leak from impact storm water sewer and soil

Action Taken or Planned:

repair or replace failed valve

Wastes Disposal Location: API sludge pit

Agencies Involved: NDDDES

Updates

Date: 7/7/2014

Status: Reviewed - Assigned to NDDoH Division

Author: Erickson, Curt

Updated Volume:

Notes:

Release due to failed valve. Waste Management Division is lead on this. Forwarded to WM director.

No follow required. Valve repaired.