

General Environmental Incident Summary

Incident: 3835 **Date/Time Notice:** 7/27/2015 2030 **DEM Incident No:**
Responsible Party: Grants Mechanical
Date Incident: 7/23/2015 **Time Incident:** 2030 **Duration:** 2.5 hours
County: Cass **Twp:** 140 **Rng:** 49 **Sec:** 26 **Qtr:**
Lat: 46.90747 **Long:** -96.83916 **Method:** Interpolation from map
Location Description: Essentia Hospital, Fargo ND. On the South West corner of the building.

Submitted By: Allen Schimmel **Affiliation:**
Address: 3239 15 th st
City: Fargo **State:** ND **Zip:** 58106

Received By:

Contact Person: Allen Schimmel
3239 15th Street
Fargo, ND 58106

Distance Nearest Occupied Building: **Release Contained:** Yes

Type of Incident: Tank Overflow

Description of Released Contaminant: Deisel Fuel

Volume Spilled: 100.00 gallons **Ag Related:** No

EPA Extremely Hazardous Substance: Unknown **Reported to NRC:** Unknown

Cause of Incident:

Control Valves on 2 of the three Generators did not close like they were suppose too. This caused the Generator Day tanks to fill up and over flow.

Risk Evaluation:

No Fuel had met with any sanitary sewers or storm.

of Fatalities: 0 **# of Injuries:** 0 **Affected Medium:** 03 - soil

Potential Environmental Impacts:

No Fuel had met with any sanitary sewers or storm.

Action Taken or Planned:

We found the problem at 8:30 pm on the 23rd day of August. We had just turned on the generators on at 6:30 the same evening, to then come back to check on them, and they were overflowing. We emedeiatly shut down the Generators. We then got equipment to excavate the spillage out of the ground and taken to the City Landfill. I had called the city emidialtly when this was discovered. They had met me out there and helped us through the situation. We excavated 25 to 30 yards of dirt out. We then brought new class 5 gravel into the sight to be backfilled. We were completed on Friday the 24th of August.

Wastes Disposal Location: Fargo City Landfill

Agencies Involved:

Updates

Date: 7/27/2015 **Status:** Reviewed - No Action Required

Author: Suess, Bill

Updated Volume: 100.00 gallons

Notes:

Hunter Hubrig with the City of Fargo is following up on this site. No additional followup is needed.