

General Environmental Incident Summary

Incident: 4006 **Date/Time Notice:** 1/22/2016 1220 **DEM Incident No:**
Responsible Party: Xcel Energy
Date Incident: 1/22/2016 **Time Incident:** 1130 **Duration:** 5 minutes
County: Stutsman **Twp:** 143 **Rng:** 63 **Sec:** 25 **Qtr:**
Lat: 47.17841 **Long:** -98.60072 **Method:** Interpolation from map
Location Description: Courtenay Wind Farm (90th Ave SE & 16th St SE, Courtenay, ND)

Submitted By: Adam Gulsvig **Affiliation:**
Address: 414 Nicollet Mall
City: Minneapolis **State:** MN **Zip:**

Received By:

Contact Person: Adam Gulsvig
414 Nicollet Mall
Minneapolis, MN 55401

Distance Nearest Occupied Building: 0.44 Miles **Release Contained:** Yes

Type of Incident: Tank Overflow

Description of Released Contaminant: Mineral Oil (Non PCB)

Volume Spilled: 100.00 gallons **Ag Related:** No

EPA Extremely Hazardous Substance: No **Reported to NRC:** Unknown

Cause of Incident:

Pressure relief valve malfunction while topping off substation transformer resulted in 100 gallons mineral oil spilled to ground surface (compacted gravel, ice & snow).

Risk Evaluation:

None.

of Fatalities: 0 **# of Injuries:** 0 **Affected Medium:** 03 - soil

Potential Environmental Impacts:

Low impact. Spilled to compacted gravel, ice and snow. Contaminated material will be cleaned up ASAP and replaced with clean fill.

Action Taken or Planned:

Badger Daylighting has been contracted to clean spill. Spill will be cleaned up using vac truck and small excavator. Clean fill will be placed shortly thereafter.

Wastes Disposal Location: Waste will be disposed of at Renewable Resources located in Killdeer, ND.

Agencies Involved:

Updates

Date: 1/22/2016 **Status:** Reviewed - Follow-up Required

Author: O'Gorman, Brian

Updated Volume:

Notes:

Spoke with the company representative via phone and was informed that the contractor was in the process of removing the materials. Documentation of the cleanup, material data and disposal records will be forwarded to the NDDoH when completed. Followup with additional correspondence and documentation.

Date: 7/18/2016 **Status:** Inspection

Author: Stockdill, Scott

Updated Volume:

Notes:

Arrived on location 7/18/2016.

No sign of spill at the time of inspection. More follow-up with the responsible party needed to ensure proper cleanup has been completed.