

General Environmental Incident Summary

Incident: 4099 **Date/Time Notice:** 5/19/2016 0937 **DEM Incident No:**

Responsible Party: Superpumper

Date Incident: 5/19/2016 **Time Incident:** 0600 **Duration:** 5 minutes

County: Stutsman **Twp:** 139 **Rng:** 64 **Sec:** 2 **Qtr:**

Lat: 46.88430 **Long:** -98.71652 **Method:** Interpolation from map

Location Description: Superpumper #26, 2315 HWY 281 South, Southeast side of the intersection of Highway 281 and I-94

Submitted By: Kris Wolla

Affiliation: Enviromental Manager

Address: 100 27th Street NE

City: Minot

State: ND

Zip: 58703

Received By:

Contact Person: Kris Wolla
100 27th Street SE
Minot, ND 58701

Distance Nearest Occupied Building: 20 Feet **Release Contained:** Yes

Type of Incident: Tank Overflow

Description of Released Contaminant: Deisel #2

Volume Spilled: 50.00 gallons **Ag Related:** No

EPA Extremely Hazardous Substance: No **Reported to NRC:** No

Cause of Incident:

Diesel Truck left the truck unattended

Risk Evaluation:

None

of Fatalities: 0 **# of Injuries:** 0 **Affected Medium:** 03 - soil

Potential Environmental Impacts:

very low chance of the diesel impregnating the concrete to get to ground water

Action Taken or Planned:

Floor Dry was spread and Strata Haz Mat is on the way to the site to clean it up properly

Wastes Disposal Location: Strata will handle any waste

Agencies Involved:

Updates

Date: 5/19/2016 **Status:** Correspondence

Author: O'Gorman, Brian

Updated Volume:

Notes:

Spoke with the company contact via phone and was informed that the release may be less than 50 gallons. Release stayed on the concrete and was contained and absorbed with Floor Dry. Contact will forward the NDDoH cleanup documentation when finished. More follow-up needed.

Date: 5/19/2016 **Status:** Reviewed - Assigned to NDDoH Division

Author: O'Gorman, Brian

Updated Volume:

Notes:

According to the report, 50 gallons of diesel were spilled on a gas station concrete parking area. More follow-up needed.

Date: 5/20/2016 **Status:** Correspondence

Author: O'Gorman, Brian

Updated Volume:

Notes:

Received an email with photos of the release. Email and photos added to report folder. Incident report forwarded to UST Program inspector. No further follow-up needed at this time.

Date: 5/23/2016 **Status:** Correspondence

Author: Vetter, Leon

Updated Volume:

Notes:

I talked to Chris Wolla. He said spill was probably closer to 10 gallons and contained immediately. Said that it did not appear that fuel went into storm sewer or infiltrated into ground. No further work should be required.