

General Environmental Incident Summary

Incident: 4152 **Date/Time Notice:** 6/29/2016 **DEM Incident No:**

Responsible Party: Jomax Construction Co. Inc

Date Incident: 6/28/2016 **Time Incident:** **Duration:**

County: Dunn **Twp:** 146 **Rng:** 96 **Sec:** 14 **Qtr:**

Lat: 47.46056 **Long:** -102.86550 **Method:** Navigation quality GPS

Location Description: Bear Creek NGL Pipeline Spread 1 Station # 247+11

Submitted By: Chase Edmiston

Affiliation:

Address: 100 West Fifth Street

City: Tulsa

State: OK

Zip: 74103

Received By:

Contact Person:

P.O. Box 701
Great Bend, ND

Distance Nearest Occupied Building:

Release Contained: Yes

Type of Incident: diesel spill

Description of Released Contaminant: Diesel fuel

Volume Spilled: 1.00 gallons

Ag Related: No

EPA Extremely Hazardous Substance: Unknown

Reported to NRC: Unknown

Cause of Incident:

Leak from water pump containment

Risk Evaluation:

Minimal impact

of Fatalities:

of Injuries:

Affected Medium: 03 - soil

Potential Environmental Impacts:

Localized area of soil was impacted. Spill occurred in upland area and no surface water or other environmentally sensitive areas were affected

Action Taken or Planned:

Upon discovery, spill was immediately contained and affected soil transported to approved disposal facility. Ineffective containment was removed from right of way.

Wastes Disposal Location:

Agencies Involved:

Updates

Date: 6/29/2016 **Status:** Reviewed - Follow-up Required

Author: Souder, Taylor

Updated Volume:

Notes:

Further follow-up is necessary and will be completed on a quarterly basis.

Date: 8/4/2016 **Status:** No Further Action Requested

Author: Washek, Sandi

Updated Volume: 1.00 gallons

Notes:

Arrived on site accompanied by the company representative. Weather was overcast with temperature of 70 degrees F. About 1 gallon of water leaked out of the water pump containment system where the company collects water from its pipe testing. Since that time, the area has received rain. There was a small puddle on site in the location of the spill. No sheen was observed on the water or on the soil. No additional follow-up needed.