

General Environmental Incident Summary

Incident: 4179 **Date/Time Notice:** 7/26/2016 0927 **DEM Incident No:**
Responsible Party: Crosby Elementary
Date Incident: 7/28/2016 **Time Incident:** 1500 **Duration:** 1 days
County: Divide **Twp:** 163 **Rng:** 97 **Sec:** 29 **Qtr:**
Lat: 48.91493 **Long:** -103.29280 **Method:** Address matching
Location Description: Crosby Elementary School, 206 1 st Street NE, Crosby ND

Submitted By: Michael Saks **Affiliation:** FCI Constructors
Address: 3070 I-70
City: Grand Junction **State:** CO **Zip:** 81504

Received By: David Cameron Health
Contact Person: Dr. Hiring
101 2nd St NE
Crosby, ND 58730

Distance Nearest Occupied Building: 10 Feet **Release Contained:** Yes

Type of Incident: Tank Leak

Description of Released Contaminant: Heating Oil

Volume Spilled: 5000.00 gallons **Ag Related:** No

EPA Extremely Hazardous Substance: Unknown **Reported to NRC:** Unknown

Cause of Incident:
over filling of tank.

Risk Evaluation:
Low

of Fatalities: 0 **# of Injuries:** 0 **Affected Medium:** 03 - soil

Potential Environmental Impacts:
Soil excavated site closed

Action Taken or Planned:
328 cubic yards of contaminated soils over excavated and hauled to landfill

Wastes Disposal Location: Noonan Landfill

Agencies Involved:

Updates

Date: 7/28/2016 **Status:** Reviewed - Assigned to NDDoH Division

Author: O'Gorman, Brian

Updated Volume:

Notes:

NDDoH Division of Waste Management Underground Storage Tank (UST) Program has jurisdiction.