

General Environmental Incident Summary

Incident: 41 **Date/Time Notice:** 4/27/2001 **DEM Incident No:**
Responsible Party: Bismarck Water Treatment Facility
Date Incident: 4/25/2001 **Time Incident:** 1800 **Duration:**
County: Burleigh **Twp:** 139 **Rng:** 80 **Sec:** 31 **Qtr:** SE
Lat: 46.81538 **Long:** -100.82690 **Method:** Derived from TRS
Location Description: Missouri River by the Bismarck water treatment facility

Submitted By: Charlie Jaszowskiak **Affiliation:**
Address:
City: **State:** **Zip:**

Received By:
Contact Person: Charlie Jaszowskiak
PO Box 5503
Bismarck , ND 58506

Distance Nearest Occupied Building: 1000 Feet
Type of Incident: pipeline leak
Description of Released Contaminant: potable water (contained chlorine less than 2.5 ppm)
Volume Spilled: **Ag Related:** No
EPA Extremely Hazardous Substance: **Reported to NRC:** Unknown

Cause of Incident:
a highlift pipe line in the water treatment facility broke discharging drinking water into the basement of the treatment plant and over ran the sump pumps and ran over the over flows going to the river.

Risk Evaluation:
none

of Fatalities: **# of Injuries:** **Affected Medium:**

Potential Environmental Impacts:
none

Action Taken or Planned:
the valves to the storage reservoir.

Wastes Disposal Location:
Agencies Involved: Local Fire Department

