



SUMMARY INFORMATION ON UNDERGROUND STORAGE TANKS

North Dakota Department of Health - Division of Waste Management
 Telephone: 701.328.5166 Fax: 701.328.5200 Web site: www.ndhealth.gov/wm
 Public Notice Rev.: 04/2008



General Information

Total Number of UST Facilities: 835 Public Record Posted Date: 10/03/2016
 Total Number of USTs: 2262 Reporting Period Dates: 10/01/2015 to 09/30/2016

Summary Information For On-Site Inspections

Number of UST Facilities Inspected: 266
 Percent Compliance: 86.99%

Summary Information For Release

Number of Confirmed UST Releases: 4

Summary Information For Release Sources and Causes

Source			Cause													
			Spill		Overfill		Phy/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	7	38.9	0	0.0	0	0.0	1	100.0	0	0.0	0	0.0	0	0.0	6	35.3
Piping	3	16.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	3	17.6
Dispenser	2	11.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	2	11.8
STP	2	11.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	2	11.8
Delivery Problem	2	11.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	2	11.8
Other	2	11.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	2	11.8
Totals	18	100.0	0	0.0	0	0.0	1	0.0	0	0.0	0	0.0	0	0.0	17	100.0

= Number of releases

% = Percent of total number of Source

Note: Release, sources and causes information are based on USTs as defined in NDAC Section 33-24-08-40. Source and cause data is collected from information provided through release reporting as required in NDAC Section 33-24-08-40. Site specific UST information on compliance and releases can be obtained upon request.